



# VERTIGO

# SPECIALIST HIGH ACCESS SERVICES

## Certificate of Compliance

### University of Adelaide North Terrace Campus Building NT39 Hub Central Roof

Inspected to comply with AS1891.4-2009 Industrial fall arrest systems and devices- Part 4: Selection, use and maintenance.

**LOCATION:** NT39 Hub Central

**Inspection ID reference:** 011901

#### **SYSTEMS IN PLACE:**

#### **9 x RIS Surface mount fall arrest anchors**

**Rating:** 15kn – One Person

**System ID**

NT39-SMAP-1  
NT39-SMAP-2  
NT39-SMAP-3  
NT39-SMAP-4  
NT39-SMAP-5  
NT39-SMAP-6  
NT39-SMAP-7  
NT39-SMAP-8  
NT39-SMAP-9 Unable to Access SMAP

#### **2 x RIS Static Lines**

**Rating:** 22kn - 2 People

**System ID**

NT39-SL-5 - FAIL  
NT39-SL-6 - FAIL

**Category:** Fall Arrest

**No of Anchors:** 9

**No of Static Lines:** 2

**Date Inspected:** 31<sup>st</sup> January 2019

**Next Inspection:** 31<sup>st</sup> January 2020

Harrison Webb  
Vertigo Specialist High Access