



VERTIGO

SPECIALIST HIGH ACCESS SERVICES

Certificate of Compliance

University of Adelaide North Terrace Campus Building NT41 – Santos School of Petroleum

Inspected to comply with AS1891.4-2009 Industrial fall arrest systems and devices- Part 4: Selection, use and maintenance.

LOCATION: NT41 Santos School of Petroleum Roof

SYSTEMS IN PLACE:

4 STATIC SAFETY LINES:

System ID: NT41-SL-1 20M
NT41-SL-2 19M
NT41-SL-3 (Tagged out of service, No longer required.)
NT41-SL-4 11M

Static Lines

LOCATION: NT41 Santos school of petroleum

System/ Unit ID: NT41-SL-01,02,04

Complying Standard: AS/NZS 1891.4.2009

Installer: Unknown
Manufacturer: Sayfa
System model: Travel 8 SMAP
Serial number: N/A
System Carrier: Pass
Max no. Users: 2
Rating: 21kn
Intermediates: 2
Fixing Design: SMAP
Load test: N/A

In service date: 12/09/2012
Inspection date: 8/1/2019
Next inspection date: 8/1/2020

Harrison Webb
Vertigo Specialist High Access