## Infrastructure HSW Management Sub-System

## **Roof Inspection Check**

#### **Building Details**

Building Name: Plant Genomics Building Building No: WT44

Date of Inspection: 23/08/2023 Keys required Roof Access and Plant Room

Risk

Medium

THE UNIVERSITY

### **Roof Access Details**

- Right of Access Permit is only for visual inspection and a different permit is required before commencing any work on the roof.
- If accessing roof externally a lock out/tag out procedure has been implemented for Fume Cupboards,
- If using a harness all workers accessing the roof must have current Working at Heights training.

Take the lift or staircase to the second floor. Enter through either plant room door 2.55 (southern corridor) or plant room door 2.56 (northern corridor), light is on right hand side. Climb stairs and exit onto enclosed platform. To access solar panels, air conditioner units use either eastern or western door located on roof platform.

Note: There is no internal access to the entrance external roof.









Entrance door

Roof platform

East side

West side

<u>No access to areas without walkways</u> unless a safe system of work is in place to ensure the risk of a fall has been minimised (2012 SA WHS Regulations Part 4), this could include using industrial fall arrest harness attached to the static lines or anchor points if available.

Roof Details				
Roof Material: Iron		No. of Roofs on Building: Two (Entrance and Main).		
<b>Pitch:</b> < 15°		Roof Height (m): 2 storeys		
Gutter Details: External Gutter		Fragile Panels / areas:		
Walkways Platforms	☑ East wing. ☑	Parapet Details (height, construction): Nil.		

Number:

Multiple.

**Description of Roof Plant:** Air conditioning Fume exhaust systems. Solar Panels

Other Details:

Static line adjacent solar panels

Warning	This process is uncontrolled when printed. The current version is available on the I&TS Website.	Effective	August 2023	Version:	3.0
Authorised	Director, Capital Projects & Facilities Management   Infrastructure Branch   Division of University	Review	August 2026	Page: 1 of 2	
Filepath	S:\Services_Resources\Infrastructure\Shared\HSW\01. Hazard Management\01 Roof Access\0	1 Risk Assessments\W	aite\2023\Plant Ge	enomics\WT44 16-	-08-23 Plant

# **Roof Inspection Check**



#### **RISK ASSESSMENT**

Rare

RISI	A ASSESSIVIEN I						
Hazards	Hazard	Risk Indicator once Controls in place	Control				
	Unprotected roof edges and height of roofs – Fall Hazard	Rare x Severe Medium	No access to roofs without a permit to work and a documented safe system of work.				
	Airbourne hazardous chemicals (Venting or Flumes)	Rare x Severe Medium	Check with Building Owner and/or Laboratory Manager and undertake a risk assessment. Contact FM for details				
	Slip/trip hazards on plant platforms and walkways.	Rare x Moderate Low	No running. Wear long sleeve trousers and safety footwear.				
	Weather – Heat, rain, strong winds – Heat exhaustion, dehydration, sunburn, colds, fall hazard	Rare x Minor Low	Do not commence works in extreme weather conditions which will adversely affect workers.				
	Working alone	Rare x Moderate Low	A system needs to be in place to ensure lone worker's welfare.				
Other Information	<ol> <li>The method of access to rooftop shall depend on the specific job task being undertaken and risk assessment completed prior to commencement of work and included in Job Safety Analysis (JSA) or Safe Work Method Statement (SWMS) or Safe Work Procedure (SWP) and Safe Work Instruction (SWI);</li> <li>Access and work on roof top when weather is clear, dry and no high winds;</li> <li>Footwear must be toe steel capped and comply with AS/NZS 2210 for type 1 safety footwear;</li> <li>Sun protection policy and procedure is in place when working outdoors;</li> <li>Tools to be carried in tool belt; and</li> <li>Plant and equipment must be well maintained and serviced regularly.</li> </ol>						
Instructions	<ol> <li>Undertake roof access in accordance with the University of Adelaide Infrastructure Management Sub-System</li> <li>Roof Access Permit to be obtained prior to roof access;</li> </ol>						
	IOOD TABLE		UENCES TABLE				
Categor		Category					
Almost	There is an expectation that an event/incident	will Severe	Injury resulting in death, permanent incapacity				
<u>certain</u> Likely	occur. There is an expectation that an event/incident occur but not certain to occur.	could Major	Injury requiring extensive medical treatment, hospitalisation, or activities could result in a Notifiable occurrence.				
Slight	light This expectation lies somewhere in the midpoint between "could" and "improbable"		Injury requires formal medical treatment (hospital outpatient/doctors visit etc), activities could result in an Improvement Notice.				
Unlikely	There is an expectation that an event/incident doubtful or <b>improbable</b> to occur	is Minor	Injury requires first aid				

doubtful or improbable to occur there is no expectation that the event/incident will Negligible Injury requires minor first aid (e.g. band aid), or result in short term discomfort (e.g. bruise, headache, occur muscular aches, etc) **RISK RATING** 

Likelihood Consequences Negligible Minor Moderate Major Severe Almost Certain High Medium Very High Very High Very High Very High Likely Medium Medium High Very High Very High High Slight Low Medium High High Unlikely Low Low Medium Medium Rare Low Low Low Medium Medium

Warning	This process is uncontrolled when printed. The current version is available on the I&TS Website.	Effective	August 2023	Version:	3.0
Authorised	Director, Capital Projects & Facilities Management   Infrastructure Branch   Division of University	Review	August 2026	Page: 2 of 2	
Filepath	S:\Services_Resources\Infrastructure\Shared\HSW101. Hazard Management\01 Roof Access\01 Risk Assessments\Waite\2023\Plant Genomics\WT44 16-08-23 Plant				